

Nail Salon Ventilation Requirements

Nail Salons must be provided with proper exhaust ventilation as described in the International Mechanical Code Table 4.3

50 cfm of exhaust per work station of intermittent exhaust or 20 cfm continuous

The exhaust must exhaust to the outside and must be captured at their source

Occupational Health Hazards in Nail Saloons

Nail Hardeners
Nail Adhesive
Nail Enamel
Polish Remover

Contain over 1000 chemicals with over 89% not tested for human contact

Of the tested products the following contains known chemicals used in nail that are a health hazard – Acetone, Benzoyl Peroxide, Butyl Acetate, Butyl Methacrylate, Camphor, Dibutyl Phthalate, Ethyl Acetate, Ethyl Cyanoacrylate, Formalin, Hydroquinone.....

Many of the nail polish paints are chemically similar to automobile paints

Permit Required

The exhaust system must be installed by a licensed Mechanical Contractor (HVAC) and permitted through the City of Savannah Mechanical Department.

Please return the attached Mechanical Permit Application to the Development Services Department located 5515 Abercorn St.



Mechanical Permit Application

INSP _____

Application Date: ____/____/____

Trades Inspections Phone Line (912) 651-6540

Mechanical Permit # _____

Instructions: All Bold Print must be completed to process this application.

If information is not provided the application will be returned.

Project Address: _____ Tax PIN: 2 - _____ - _____

Owner: _____ Phone#: () _____ - _____

Address: _____ City: _____ State: _____ Zip: _____

Date Ready for Inspection: _____

Gas Release date: ____/____/____/

Inspection Type: _____ By _____

Inspection will be performed date received if a date is not indicated or "will call" is written in.

This Section Must Be Completed

List of Equipment and Systems to be installed:

New: ☐ Replacement: ☐

Equipment	Size/#	Equipment	Size/#	Equipment	Size/#
Distribution System	_____	A/C Units	_____	Gas Furnace	_____
Grease Hoods	_____	Heat Pumps	_____	Unit Heater	_____
Exhaust Systems	_____	Package Units	_____	Condensers	_____
Gas Piping (Total Ft)	_____	Space Heaters	_____	Coolers	_____

Other _____

Detailed Description of Work: _____

Valuation \$ _____ Fee Due \$ _____ Fee Pd \$ _____ Bank _____ Ck# _____

Note: Minimum fee \$32.00

Name of Company performing this work: _____

Address: _____ City: _____ State: _____ Zip: _____

Phone # () _____ Cell# () _____ Email | Fax: _____

/ ☐ 1 ☐ 2

Signature of State Licensed Contractor

State License No. and Class

Approved

NOTICE

THE ISSUANCE OF THIS PERMIT AUTHORIZES IMPROVEMENTS OF THE REAL PROPERTY DESIGNATED HEREIN WHICH IMPROVEMENTS MAY SUBJECT SUCH PROPERTY TO MECHANIC'S AND MATERIALMEN'S LIENS PURSUANT TO PART 3 OF ARTICLE 8 OF CHAPTER 14 OF TITLE 44 OF THE OFFICIAL CODE OF GEORGIA ANNOTATED. IN ORDER TO PROTECT ANY INTEREST IN SUCH PROPERTY AND TO AVOID ENCUMBRANCES THEREON, THE OWNER OR ANY PERSON WITH AN INTEREST IN SUCH PROPERTY SHOULD CONSIDER CONTACTING AN ATTORNEY OR PURCHASING A CONSUMER'S GUIDE TO THE LIEN LAWS WHICH MAY BE AVAILABLE AT BUILDING SUPPLY HOME CENTERS.

DIG SAFELY!!! CALL 1-800-282-7411, 72 HOURS (EXCLUDING WEEKENDS AND HOLIDAYS) BEFORE YOU DIG OR WORK WITHIN 10' OF A HIGH VOLTAGE LINE. IT'S THE LAW!! THIS ALLOWS UNDERGROUND UTILITIES TO BE MARKED. www.digsafe.com

Your permit is valid for six months, provided the work is not suspended or abandoned. NOTE: The permit becomes invalid if work is suspended or abandoned for a period of six months after the time the work has commenced. Abandonment is tracked by inspection activity within the Inspection's permit data base.